



aitex[®]
research & innovation center

FIRE BEHAVIOUR

Applicant:

ROSCO IBERICA,S.A


Calle del Oro 76 pol ind Sur
ES-28770 COLMENAR VIEJO
Madrid

Is authorized to place the label "Curtains Fire Performance Classification" label according to the 2025AN2074.



CLASSIFICATION OF FIRE BEHAVIOUR: CURTAINS

Nº: 25AN2074



The sample referenced as:

"Artículo softdrop"

MATERIAL:

Fabric with an undefined pattern in green and grey tones on one side and white on the other.
Composition: 100% cotton , with a weight of 280 g/m².

Has been tested according to the standards EN 1101:1995+A1:2005 and EN 13772:2011, not cleanable material, according to client. The classification according to standard EN 13773:2003 is:

"CLASS 1"

Date of Issue

30st of July 2025



Date: 06/08/2025 10:11:48

Digitally Signed by:JOAN RISUEÑO CABANES -
NIF:48605765A

Joan Risueño
Head of Fire Behaviour lab.